

Fire Protection Survey Services™

P.O. Box 170
Longford Mills, Ontario, Canada, L0K 1L0
Telephone: (705) 689-6183 Fax: (208) 474-3520
E-mail: firepss@bell.net Website: www.fpss.ca

Fire Department Water Tanker Shuttle Accreditation

Presented To: Douro-Dummer Township

ACCREDITED FIRE STATIONS

Donwood Fire Station #1

Douro Fire Station #2

Warsaw Fire Station #4

Date Test Passed: July 11th, 2013

Flow Achieved: 220 I.G.P.M. 1000 LITERS/MIN.

Two (2) Hour Test Time



Signed: *Peter J. Rose*

Peter J. Rose, C.E.T., F.P.T.
Principal Partner
Senior Fire Protection Specialist
Senior Loss Control Specialist

This Certificate Expires on August 1st, 2018

FPSS "Professionalism With Pride"®